

Han Q 4/2-M insert with QL 2,5-6mm²



| Part number | 09 12 006 2662 |
|--------------------|---|
| Specification | Han Q 4/2-M insert with QL 2,5-6mm ² |
| HARTING eCatalogue | https://b2b.harting.com/09120062662 |

Image is for illustration purposes only. Please refer to product description.

Identification

| Category | Inserts |
|----------------|--------------------|
| Series | Han [®] Q |
| Identification | 4/2 |

Version

| Termination method | Axial screw termination |
|---------------------------|--|
| Gender | Male |
| Size | Han-Compact [®] |
| Number of contacts | 6 |
| Number of signal contacts | 2 |
| Number of power contacts | 4 |
| PE contact | Yes |
| Details | With Han-Quick Lock [®] signal contacts |

Technical characteristics

| Conductor cross-section | 2.5 6 mm² 0.25 1.5 mm² Signal |
|-----------------------------------|----------------------------------|
| Rated current | 40 A |
| Rated voltage conductor-earth | 400 V |
| Rated voltage conductor-conductor | 690 V |
| Rated impulse voltage | 6 kV |
| Pollution degree | 3 |
| Rated current (signal) | 10 A |

Page 1 / 3 | Creation date 2023-01-05 | Please note that the data specified here were taken as extracts from the online catalogue. Please refer to the user documentation for the complete and up-to-date information and data. Please also note that the user is responsible for validating functionality, conformity with applicable laws and directives, as well as for the electrical safety in the particular application. HARTING Stiftung & Co. KG | Marienwerderstr. 3 | 32339 Espelkamp | Germany



Technical characteristics

| Rated voltage (signal) | 250 V |
|---------------------------------|---------------------|
| Rated impulse voltage (signal) | 4 kV |
| Pollution degree (signal) | 3 |
| Insulation resistance | >10 ¹⁰ Ω |
| Contact resistance | ≤0.3 mΩ |
| Contact resistance, signal area | <3 mΩ |
| Tightening torque | 1.8 Nm |
| Limiting temperature | -40 +125 °C |
| Mating cycles | ≥500 |

Material properties

| Material (insert) | Polycarbonate (PC) |
|---|--|
| Colour (insert) | RAL 7032 (pebble grey) |
| Material (contacts) | Copper alloy |
| Surface (contacts) | Silver plated |
| Material flammability class acc. to UL 94 | V-0 |
| RoHS | compliant with exemption |
| RoHS exemptions | 6(c): Copper alloy containing up to 4 % lead by weight |
| ELV status | compliant with exemption |
| China RoHS | 50 |
| REACH Annex XVII substances | Not contained |
| REACH ANNEX XIV substances | Not contained |
| REACH SVHC substances | Yes |
| REACH SVHC substances | 6,6'-di-tert-butyl-2,2'-methylenedi-p-cresol Lead |
| ECHA SCIP number | 5dbb3851-b94e-4e88-97a1-571845975242 |
| California Proposition 65 substances | Yes |
| California Proposition 65 substances | Lead Nickel Naphthalene |
| Fire protection on railway vehicles | EN 45545-2 (2020-08) |
| Requirement set with Hazard Levels | R22 (HL 1-3) R23 (HL 1-3) |
| | |

Page 2 / 3 | Creation date 2023-01-05 | Please note that the data specified here were taken as extracts from the online catalogue. Please refer to the user documentation for the complete and up-to-date information and data. Please also note that the user is responsible for validating functionality, conformity with applicable laws and directives, as well as for the electrical safety in the particular application. HARTING Stiftung & Co. KG | Marienwerderstr. 3 | 32339 Espelkamp | Germany

Product data sheet 09 12 006 2662 Han Q 4/2-M insert with QL 2,5-6mm²



Specifications and approvals

| Specifications | IEC 60664-1 IEC 61984 |
|-----------------|--|
| Approvals | DNV GL |
| UL / CSA | UL 1977 ECBT2.E235076 CSA-C22.2 No. 182.3 ECBT8.E235076 |
| Commercial data | |

| Packaging size | 10 |
|--------------------------------|---|
| Net weight | 46.34 g |
| Country of origin | Romania |
| European customs tariff number | 85366990 |
| GTIN | 5713140017283 |
| eCl@ss | 27440205 Contact insert for industrial connectors |

Page 3 / 3 | Creation date 2023-01-05 | Please note that the data specified here were taken as extracts from the online catalogue. Please refer to the user documentation for the complete and up-to-date information and data. Please also note that the user is responsible for validating functionality, conformity with applicable laws and directives, as well as for the electrical safety in the particular application. HARTING Stiftung & Co. KG | Marienwerderstr. 3 | 32339 Espelkamp | Germany